

## Storm Drain Protector Performance Data - Transformer Oil

Initial EPH Concentration in Water (mg/L)	Transformer Oil (EPH) Concentration in Water After Passing Through Storm Drain Protector		Transformer Oil (EPH) Removal %
	Extractable Petroleum Hydrocarbons (EPH w10-19)	Extractable Petroleum Hydrocarbons (EPH w19-30)	
53.8	0.9 ppm	0.9 ppm	96.5%
56.2	1.9 ppm	1.5 ppm	94.5%
58.9	0.2 ppm	0.2 ppm	99.2%
64.6	0.5 ppm	0.4 ppm	98.5%

## Storm Drain Protector Performance Data - PCB's

Initial PCB Concentration in Water (mg/L)	PCB Concentration After Passing Through Storm Drain Protector (mg/L)	PCB Removal %
0.13	0.0011 ppb	100%
0.135	0.0003 ppb	100%
0.179	<0.0002 ppb	99.1%
0.222	<0.0002 ppb	99.1%